

# Thermal 1 RU Inlet Duct for Cisco Nexus<sup>^</sup> 9372 and 9332 Switches

## specifications

The inlet duct shall be designed using CFD modeling and actual thermal lab verification, and shall be compatible with Cisco Nexus<sup>^</sup> 9372 and Nexus<sup>^</sup> 9332. The inlet duct shall optimize thermal performance by directing air from the cold aisle to the switch inlet preventing hot air recirculation. The use of passive inlet duct shall lower the average switch inlet temperature by 12°F to 22°F; resulting in reduced energy costs. The modular duct shall be capable of being installed in retro-fit applications and allow access to fan and power supply modules without disrupting existing in-cabinet equipment and cabling.



### Top-of-Rack Switches

Nexus 9372PX - CID1RU22-23DB1  
Nexus 9372PX-E - CID1RU22-23DB1  
Nexus 9372TX - CID1RU22-23DB1  
Nexus 9372TX-E - CID1RU22-23DB1  
Nexus 9332PQ - CID1RU22-23DB1

## technical information

### Dimensions:

**CID1RU22-23DB1 (1RU):** 8.5" – 9.4"D (adjustable) x 1.80"H x 18.3"W  
(215 – 240.2mm D x 45.8mm H x 465mm W)

## key features and benefits

<b>Direct cool air to the switch:</b>	Increases energy efficiency in ToR applications and allows high density server applications
<b>Passive inlet duct:</b>	No additional moving parts or power required
<b>Day one or two installation:</b>	Eliminates the requirement to replace or disturb existing cabinets, equipment and infrastructure for lower capital expenditures and minimized risk
<b>Compatible with Panduit Server (S-Type) Cabinets:</b>	Allows maximum thermal efficiency.
<b>Allows for installation in cabinets with mounting depths from 28.2" – 30.2" (717mm – 767mm):</b>	Allows greater network flexibility and reliability
<b>Allows access to power supplies and fan blades:</b>	Allows ease of maintenance
<b>Support bracket supports switch during installation</b>	Allows single person ease of switch installation

## applications

Top of Rack (ToR) switches, such as the Cisco Nexus<sup>^</sup> 9000 series, are designed to meet the server-access networking requirements of the virtualized data center. When deployed within server cabinets or racks, the modular duct provides a cool air path to the air intakes of the switch. By providing a path for cool air to the switch, data center temperature set points can be raised – resulting in higher energy efficiencies and lower operating costs.

<sup>^</sup>Cisco and Cisco Nexus are registered trademarks and Cisco ACI is a trademark of Cisco Systems, Inc. and/or its affiliates in the United States and certain other countries.

### WORLDWIDE SUBSIDIARIES AND SALES OFFICES

PANDUIT CANADA  
Markham, Ontario  
cs-cdn@panduit.com  
Phone: 800.777.3300

PANDUIT EUROPE LTD.  
London, UK  
cs-emea@panduit.com  
Phone: 44.20.8601.7200

PANDUIT SINGAPORE PTE. LTD.  
Republic of Singapore  
cs-ap@panduit.com  
Phone: 65.6305.7575

PANDUIT JAPAN  
Tokyo, Japan  
cs-japan@panduit.com  
Phone: 81.3.6863.6000

PANDUIT LATIN AMERICA  
Guadalajara, Mexico  
cs-la@panduit.com  
Phone: 52.33.3777.6000

PANDUIT AUSTRALIA PTY. LTD.  
Victoria, Australia  
cs-aus@panduit.com  
Phone: 61.3.9794.9020

For a copy of Panduit product warranties, log on to [www.panduit.com/warranty](http://www.panduit.com/warranty)

For more information

Visit us at [www.panduit.com](http://www.panduit.com)

Contact Customer Service by email: [cs@panduit.com](mailto:cs@panduit.com)  
or by phone: 800.777.3300